





SPECTRAPURE®

INNOVATORS IN WATER TECHNOLOGY SINCE 1985

COPYRIGHT©2007 ALL RIGHTS RESERVED

NOTES:

REPRESENTS WHAT IS CONTAINED IN KIT

MAKE SURE YOU INSTALL THE "IN" AND "OUT" PORTS IN CORRECT LOCATIONS

THE 1 LB CHECK VALVE HAS AN ARROW POINTING IN THE DIRECTION WHERE THE WATER FLOWS

THE FLOAT USES A 9/16" HOLE.

IF YOUR HOUSE PRESSURE IS BELOW 40 PSI, THE WASTE WATER WILL NOT SHUT OFF WITH THIS KIT. IT THIS HAPPENS, YOU NEED TO PURCHASE A BOOSTER PUMP OR AN LLC.

INFORMATION

PROJECT: INSTALLATION FOR ASOFK ON RO & RO/DI SYSTEMS

DATE: 5-14-07

SCALE: N.T.S

The contents of this drawing are the sole property of SpectraPure . No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise without the prior written permission of SpectraPure . 2007

REVISIONS

DATE:	REV #

SHEET #

1/1